


Energy Efficiency Report



FirstRate Report



YOUR HOUSE ENERGY RATING IS: ★★★★★★ **6 STARS**
in Climate: 24 **SCORE: 35 POINTS**


Name: Tod Consultancies P/L ATF 4 Stars Superannuation Fund

Ref No: 55029

House Title: Unit 6 Block 8 Section 46 TURNER

Date: 21-05-2024

Address: 6/11 Forbes Street, Turner ACT 2612



This rating only applies to the floor plan, construction details, orientation and climate as submitted and included in the attached Rating Summary. Changes to any of these could affect the rating.

IMPROVING YOUR RATING

The table below shows the current rating of your house and its potential for improvement.

	POOR			AVERAGE				GOOD			V. GOOD	
Star Rating	0 Star	★	★★	★★★	★★★★	★★★★★	★★★★★★	★★★★★★★	★★★★★★★★	★★★★★★★★★		
Point Score	-71	-70	-46	-45	-26	-25	-11	-10	4	5	16	17
Current	35	<input type="text"/>										
Potential	35	<input type="text"/>										

Incorporating these design options will add the additional points required to achieve the potential rating shown in the table. Each point represents about a 1% change in energy efficiency. This list is only a guide to the range of options that could be used.

Design options

Additional points

ORIENTATION

Orientation is one of the key factors which influences energy efficiency. This dwelling will achieve different scores and star ratings for different orientations.

Current Rating	35	★★★★★★
-----------------------	-----------	---------------

Largest windows in the dwelling;

Direction : ESE

Area : 7 m²

The table below shows the total score for the dwelling when these windows face the direction indicated.

Note that obstructions overshadowing windows have been removed from all windows in these ratings to allow better comparisons to be made between orientations.

ORIENTATION	POINT SCORE	STAR RATING
1. East	39	★★★★★★
2. South East	33	★★★★★★
3. South	34	★★★★★★
4. South West	40	★★★★★★
5. West	47	★★★★★★
6. North West	57	★★★★★★
7. North	57	★★★★★★
8. North East	52	★★★★★★

FirstRate Mode
Climate: 24

RATING SUMMARY for: Unit 6 Block 8 Section 46 TURNER, 6/11 Forbes Street, Turner ACT 2612,

Assessor's Name:

Net Conditioned Floor Area: 47.1 m²

				Points		
Feature				Winter	Summer	Total
CEILING				8	0	8
Surface Area:	0	Insulation:	8			
WALL				3	0	3
Surface Area:	-3	Insulation:	6	Mass:	0	
FLOOR				21	-5	16
Surface Area:	17	Insulation:	-5	Mass:	3	
AIR LEAKAGE (Percentage of score shown for each element)				9	0	9
Fire Place	0 %	Vented Skylights	0 %			
Fixed Vents	0 %	Windows	52 %			
Exhaust Fans	28 %	Doors	0 %			
Down Lights	0 %	Gaps (around frames)	20 %			
DESIGN FEATURES				0	0	0
Cross Ventilation	0					
ROOF GLAZING				0	0	0
Winter Gain	0	Winter Loss	0			
WINDOWS				-23	-9	-32
Window Direction	Area		Point Scores			
	m2	%NCFA	Winter* Loss	Winter Gain	Summer Gain	Total
ESE	7	14%	-30	15	-5	-21
SSW	3	7%	-14	7	-4	-11
Total	10	21%	-45	22	-9	-32

* Air movement over glazing can significantly increase winter heat losses. SEAV recommends heating/cooling duct outlets be positioned to avoid air movement across glass or use deflectors to direct air away from glass.

The contribution of heavyweight materials to the window score is 0 points

				Winter	Summer	Total
RATING	★★★★★★			17	-14	35*

* includes 31 points from Area Adjustment

Detailed House Data

House Details

ClientName Tod Consultancies P/L ATF 4 Stars Superannuation Fund
HouseTitle Unit 6 Block 8 Section 46 TURNER
StreetAddress 6/11 Forbes Street, Turner ACT 2612
FileCreated 21-05-2024

Climate Details

State
Town
Postcode
Zone 24

Floor Details

ID	Construction	Sub Floor	Upper	Shared	Foil	Carpet	Ins RValue	Area
1	Suspended Slab	Enclosed	No	Yes	No	Float Timb	R0.0	33.5m ²
2	Suspended Slab	Enclosed	No	Yes	No	Carp	R0.0	13.5m ²
3	Suspended Slab	Enclosed	No	Yes	No	Tiles	R0.0	5.5m ²

Wall Details

ID	Construction	Shared	Ins RValue	Length	Height
1	Framed: FC Sheet Clad	Yes	R0.0	9.2m	2.4m
2	Brick Veneer	No	R2.0	13.0m	2.4m
3	Brick Veneer	No	R2.5	8.5m	2.4m

Ceiling Details

ID	Construction	Shared	Foil	Ins RValue	Area
1	Attic - Low Ventilation	No	Yes	R5.0	52.5m ²

Window Details

ID	Dir	Height	Width	Utility	Glass	Frame	Curtain	Blind	Fixed & Adj Eave	Fixed Eave	Head to Eave
1	ESE	2.4m	2.4m	No	SG	ALIMPR	VB	No	0.0m	0.0m	0.0m
2	SSW	2.4m	0.4m	No	SG	ALIMPR	HB	No	0.0m	0.0m	0.0m
3	SSW	2.4m	0.4m	No	SG	ALIMPR	HB	No	0.0m	0.0m	0.0m
4	ESE	2.4m	0.4m	No	SG	ALIMPR	HB	No	0.0m	0.0m	0.0m
5	SSW	0.6m	2.4m	No	SG	ALIMPR	HB	No	0.0m	0.0m	0.0m

Window Shading Details

ID	Dir	Height	Width	Obst Height	Obst Dist	Obst Width	Obst Offset	LShape Left Fin	LShape Left Off	LShape Right Fin	LShape Right Off
1	ESE	2.4m	2.4m	0.0m	0.0m	0.0m	0.0m	2.0m	0.0m	2.0m	0.0m

Zoning Details

Is there Cross Flow Ventilation ? Average

Air Leakage Details

Location Suburban
Is there More than One Storey ? No
Is the Entry open to the Living Area ? No
Area of Heavyweight Mass 0m²
Area of Lightweight Mass 0m²

	<u>Sealed</u>	<u>UnSealed</u>
Chimneys	0	0
Vents	0	0
Fans	1	0
Downlights	0	0
Skylights	0	0
Utility Doors	1	0
External Doors	0	0
Unflued Gas Heaters		0
Percentage of Windows Sealed		98%
Windows - Average Gap		Small
External Doors - Average Gap		Small
Gaps & Cracks Sealed		Yes

Insurance Certificates & Tax Invoice





Pest Controllers Combined Liability Certificate of Currency

The Policy below is current until 4.00pm on the expiry date shown below

INSURED: ACT Property Inspections Pty Ltd

BUSINESS DESCRIPTION: General Pest & Weed Control
Timber Pest Inspections
Termite Barrier Installations
Pre-Purchase House Pest Inspections
Building Inspections (Non-Pest Related)
Energy Efficiency Ratings
Compliance Reports

POLICY REFERENCE: 09A349653PLB

PERIOD OF INSURANCE: From: 4.00pm on 30/03/2024
To: 4.00pm on 30/03/2025

POLICY CLASS: Pest Controllers Combined Liability

SUMS INSURED: **Section 1: General Public & Products Liability**

\$20,000,000 Our maximum liability in respect of any claim or series of claims for Personal Injury, Property Damage or Advertising Liability caused by or arising out of any one occurrence; and

\$20,000,000 Our total aggregate liability during any one period of insurance for all claims arising out of Your Product

Section 2: Professional Indemnity

\$5,000,000 Our maximum liability in respect of any Claim or any series of Claims inclusive of costs and expenses.

\$10,000,000 Our total aggregate liability for all Claims inclusive of costs and expenses.

This Certificate of Currency is subject to the Policy Documentation to be read in conjunction with the Definitions, Conditions and Exclusions in the Pest Controllers Combined Liability Insurance Policy.

Date Issued: 22 March 2024



**ACT
PROPERTY
INSPECTIONS**

TAX INVOICE

Tod Consultancies P/L ATF 4 Stars Superannuation Fund
6/11 Forbes St
TURNER ACT 2612
AUSTRALIA

Invoice Date
17 May 2024

Invoice Number
INV-55029

ABN
33 600 397 466

ACT Property Inspections
(02) 6232 4540
Unit 1, 33 Altree Ct
PHILLIP ACT 2606
ABN: 33 600 397 466

Description	Quantity	Unit Price	GST	Amount AUD
Energy Efficiency Report	1.00	347.05	10%	347.05
ACTPLA - EER ESDD Lodgement Fee (no GST)	1.00	43.24	GST Free	43.24
			Subtotal	390.29
			TOTAL GST 10%	34.71
			TOTAL AUD	425.00

Due Date: 28 May 2024

Payment Terms: 7 Day Account

Please pay within the payment terms to avoid an admin fee. Note: all bank/legal fees incurred in obtaining payment will be the customer's responsibility

Direct Deposit

BSB: 012084

Account Number: 194679655

Account Name: ACT Property Inspections Pty Ltd

Please reference your name and invoice number

Cheques - please make payable to ACT Property Inspections Pty Ltd

[View and pay online now](#)



**ACT
PROPERTY
INSPECTIONS**

RECEIPT

Tod Consultancies P/L ATF 4 Stars Superannuation Fund
6/11 Forbes St
TURNER ACT 2612
AUSTRALIA

Payment Date
17 May 2024

Sent Date
18 May 2024

ABN:
33 600 397 466

ACT Property Inspections
(02) 6232 4540
Unit 1, 33 Altree Ct
PHILLIP ACT 2606
ABN: 33 600 397 466

Total AUD paid	425.00
-----------------------	---------------

Invoice Date	Reference	Payment Reference	Invoice Total	Amount Paid	Still Owing
17 May 2024	INV-55029	Payment	425.00	425.00	0.00
			Total AUD	425.00	0.00
